LAPI LABORATORIO PREVENZIONE INCENDI S.p.A.
Sede Primaria: I-59100 PRATO - Via della Quercia, 11
Telefono +39 0574.575.320 - Telefax +39 0574.575.323
Sede Secondaria: I-50041 CALENZANO (FI) - Via Petrarca, 48
e-mail: lapi@laboratoriolapi.it
web site: www.laboratoriolapi.it

Reg. 305/2011
Notified Body N°0987

Certificate of Evaluation and Verification of Constancy of Performance
0987-CPR-156

In compliance with the Regulation UE 305/2011 on the approximation of law, regulations and administrative provisions of the Member States relating to the construction products , it has been stated that:

the building product denominated:

TORO/APIROS/FAGGIO

Description of the product:

Beech plywood raw panel, thickness from 6 mm to 35 mm for internal use as a non-structural component in wet conditions

Type: **Plywood raw panel**
Use: **Internal finishings as a non-structural component for use in wet conditions**
End use: **Wall / ceiling panel not in contact with any support or laid on non-combustible substrates classified as Euroclasses A1 or A2.**

Produced by:

COMPENSATI TORO S.p.A.
Via Piverone, 4 - 10010 AZEGLIO (TO) - (Italy)

in the factory of:

Via Piverone, 4 - 10010 AZEGLIO (TO) - (Italy)

is submitted by the manufacturer to the factory production control (FPC) under **System 1** and to the testing of samples (ITT) by the Notified body for Certification, Inspection and Testing according to Regulation UE 305/2011. The Notified Body (**LAPI SpA - Laboratorio Prevenzione Incendi N° 0987**) has performed the initial type testing on the samples taken at the factory in accordance with the described test for the relevant characteristics of the product, the initial inspection of the factory and the factory production control and it will perform the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning to the System 1 and the performances described in Annex ZA of the standard

EN 13986:2004 (for non-structural use only)

"Wood-based panels for use in construction – Characteristics, evaluation of conformity and marking"

are performed and the product complies with characteristics required as for:

Bending strength EN 310
Glueing quality EN 314-2
Release of formaldehyde: class E1
Moreover Euroclass for reaction to fire according to UNI EN 13501-1:2009 is:

B-s1, d0

CE

This certificate, issued without test repetition, is the renewal of certificate n. 0987-cpd-156, first issued on 07/06/2010. This certificate is issued on 07/06/2015 and it remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or as long as the factory production control itself are not modified significantly and latest on 06/06/2020.

Prato, 07/06/2015

LAPI SPA - LABORATORIO PREVENZIONE INCENDI - n. 0987

Il Direttore del Laboratorio
Dr. Luca Ermini

Il presente Rapporto di Prova non può essere riprodotto in forma parziale senza l'autorizzazione scritta di questo Laboratorio