



LAPI LABORATORIO PREVENZIONE INCENDI S.p.A.

Sede Primaria: I-59100 PRATO - Via della Quercia, 11  
Telefono +39 0574.575.320 - Telefax +39 0574.575.323

Sede Secondaria: I-50041 CALENZANO (FI) - Via Petrarca, 48  
e-mail: lapi@laboratoriolapi.it  
web site: www.laboratoriolapi.it

Notified Body N°0987



Member of European Group of Organisations for Fire  
Testing, Inspection and Certification

## Certificate of Evaluation and Verification of Constancy of Performance 0987-CPR-137

in compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of law, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive – CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that:

*the building product denominated:*

**TORO/APIROS/CEIBA**

*Description of the product:*

**Fromager plywood raw panel, thickness from 9 mm to 50 mm for internal use as a non-structural component in wet conditions**

Type: Plywood raw panel

Use: Internal finishings as a non-structural component for use in wet conditions

End use: Floor element not in contact with any support or laid on non-combustible substrates classified as Euroclasses A1<sub>fl</sub> or A2<sub>fl</sub>.

*Produced by:*

**COMPENSATI TORO S.p.A.**

Via Piverone, 4 - 10010 AZEGLIO (TO) - (Italy)

*in the factory of:*

Via Piverone, 4 - 10010 AZEGLIO (TO) - (Italy)



is submitted by the manufacturer to the factory production control (FPC) under **system 1** and to the testing of samples (ITT) by the Notified body for Certification, Inspection and Testing according to Regulation UE 305/2011. The Notified Body (**LAPI S.p.A. - Laboratorio Prevenzione Incendi N° 0987**) has performed the initial type testing on the samples taken at the factory in accordance with the described test for the relevant characteristics of the product, the initial inspection of the factory and the factory production control and it will perform the continuous surveillance, assessment and approval of the factory production control.

**This certificate attests that all provisions concerning to the System 1 and the performances described in Annex ZA of the standard**

**EN 13986:2004 (for non-structural use only)**

**"Wood-based panels for use in construction – Characteristics, evaluation of conformity and marking"**

**are performed and the product complies with characteristics required as for:**

Bending strength EN 310

Glueing quality EN 314-2

Release of formaldehyde: class E1

**Moreover Euroclass for reaction to fire according to EN 13501-1:2007 is:**

**B<sub>fl</sub>-s1**



This renewal of the certificate issued for the first time on 20/02/2009, was released on 20/02/2014 without repetition of tests and it remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or as long as the factory production control itself are not modified significantly and latest until 19/02/2019

Prato, 20/02/2014

**The Technical Director**

Dr. Luca Ermini